

FORM-V
FIRE SAFETY CERTIFICATE

(See rule-13(3) of the Odisha Fire Prevention and Fire Safety Rules, 2017)

File No. 02/2019

Certificate No 02/2019 /FPW Dated: 10.05.2019

This Certificate is valid up to: 11.05.2021 (Condition apply)

(Apply for renewal at least three months before expiry)

Certified that Kalinga Eye Hospital, DakshinaKali Road, Dhenkanal (name of building/premises) situated at (address) Dakshinakali Road, Dhenkanal consisting of total 1 (one) B+G+3 number of Towers/Blocks, was inspected by officers of the Fire Service on 06.05.2019 in presence of (name of owner or his representative) Deputy Director Sri Sunil Kumar Mishra and it has been found to comply with the fire prevention and safety requirements in accordance with the Odisha Fire Prevention and Fire Safety Rules, 2017 and that its various floors are fit for occupancy or usage as noted hereunder against each subject to compliance to the conditions as prescribed herein below:

1. Lower Basement/Underground in Tower/Block.....usage Parking (Ramp to be Provided & kitchen should be shifted)
2. Upper Basement/ Underground in Tower/Block.....usage Nil
3. Ground floor in Tower/Block - usage - Hospital (OPD, Doctors chamber, Lab, Reception room, Medicine shop, Lobby, Toilet etc.) short fall to be complied.
4. Stilt in Tower/Block.....usage Nil
5. Mezzanine in Tower/Block.....usage Nil
6. Upper Floors in Tower/Block - usage - Doctor chambers, Nursing room, OT, etc (short fall to be complied)
7. Upper Floors in Tower/Block - usage - Hospital bed room, waiting room, Toilet, etc (short fall to be complied)
8. Upper Floors in Tower/Block usage 3rd floor un-used / vacant rooms & deviated should be approved by DRIT, Dhenkanal

CONDITIONS:

1. Fire prevention and safety measures and appliances, availability of water supplies and means of access thereto etc provided in the building or premises, should be maintained by the occupier (s) in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The set-backs, driveways, entrance gates, exits, staircases, corridors and escape ways should not be changed, obstructed or modified in any way.
3. The occupiers (s) shall train all staff and occupants periodically to make them well conversant in use and operation of the fire prevention and safety measures.
4. Fire drills/rehearsals should be organised at least once in six months by involving Local Fire Station.
5. The occupier (s) shall appoint Fire Safety Supervisor exclusively for this building or premises.
6. Photocopies of this Certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in all floors of all Towers/Blocks of building/premises.

By order of the Director of Fire Service

DR No. 228/Angul Circle, Angul Dt. 10.05.2019


Signature with Seal

Name and Designation of Issuing Officer :- Chandra Mohan Routray
Deputy Fire Officer, Angul Circle, Angul

Deputy Fire Officer
Angul Circle, Angul